

Handrail on stairs not long enough to go nosing to nosing. Closed-in room under stairs not part of approved permit.



Lower handrail requires 2" clearance from wall to comply with building permit.



Upper handrail requires 2" clearance from wall to comply with building code.



Decking surface not an approved product as required by the BC Building Code, Section 9.26.