

Accessory building locations.



Accessory building #1, 246 sq ft in size.



Elevated ramp requiring guard rail.



Concrete columns, but footings and soil bearing capacity unknown.



Framing construction materials are not pressure treated, as required within 18" of grade.



Building #2, 225 sq ft in size.



Rear elevation appears to be located within the setback area, footings and floor framing not visible at time of inspection.



Finished interior of building #2.



Foundations not visible at time of inspection.



Accessory building #3, less than 108 sq ft, no building permit required, but appears to be within side yard setback area.